

Building	Value	Repair cost Estimate (Not Final)	Code issues	Suggestion
Pine Island Restroom	\$22,630	\$11,315	Significant damage.	Portable Restroom Facility
Port Authority Building	\$127,428	N/A	Significant damage.	Port Authority is budgeted for demolition in the current budget after environmental study is done.
Water Ways Building	\$74,475	\$100,000	Flooded twice	Demolition of Building, Temporary location at another site outside of flood zone. Build new Building to Code if needed on site
Coast Guard Building	\$328,612	In Process	Pre-FIRM. Electric, mechanical below flood elevation. Flooded twice	Repair electric, mechanical to meet Code for flood zone.